



CERTIFICADO AENOR DE PRODUCTO Nº 030 / 002092
AENOR PRODUCT CERTIFICATE Nº

La Asociación Española de Normalización y Certificación (AENOR) certifica que el producto
The Spanish Association for Standardisation and Certification (AENOR) certifies that the product

**ELECTRODOS DE PUESTA A TIERRA PARA INSTALACIONES DE BAJA TENSIÓN
EN EDIFICIOS. PICAS CILINDRICAS ACOPLABLES DE ACERO-COBRE**

**GRUNDING ELECTRODES FOR LOW VOLTAGE ELECTRICAL INSTALLATION OF BUILDINGS.
COMPLING CYLINDRICAL BARS OF STEEL-COPPER.**

Referencia Type reference	Clase de pica Rod type	Longitud útil Effective length	Marca Comercial: Trademark:		Espesor de la capa de cobre Thickness of copper layer	Información adicional Additional information
			Diámetro Diameter			
500PTT1514	Lisa/Smooth	1500 mm	14,2 mm		0,1 mm	---
500PTT2014	Lisa/Smooth	2000 mm	14,2 mm		0,1 mm	---

suministrado por

supplied by

NAPOLEON ARMENGOL, S.A.
CL JUAN MIRO, 12-14 PI CAN HUMET
08213 POLINYA (Barcelona - ESPAÑA)

y elaborado en

and manufactured in

G, 1201, GIDC, METODA, LODHIKA, DIT: RAJKOT
(INDIA)

es conforme con

complies with

UNE 202006:2005

Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 30.21.

In order to grant this Certificate, AENOR has tested the product and has verified the quality system used in its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with the stipulations of the Specific Rules RP 30.21.

Fecha de concesión: **2008-01-29**
First issued on:

Fecha de caducidad: **2013-01-29**
Expires on:


El Director General de AENOR
General Manager